

Name of Inspector: Mark A. Randazzo/O'Brien & Gere Engineers

Signature: 

Date of Inspection: April 12, 2017

Time Inspection Started: 1230 hours

Facility Status: Racing day

1) UPON COMPLETION, RETURN THIS FORM AND REPORT ALL IDENTIFIED PROBLEMS IMMEDIATELY TO THE WEP COORDINATOR.

Key: Satisfactory - S, Not Applicable - NA See Comment Section - C	AREAS SUBJECT TO INSPECTION															Additional Comments (Deficiencies and Remedies)
	Barn 1	Barn 2	Barn 3	Barn 4	Barn 5	Barn 6	Barn 7	Barn 8	Barn 9	Barn 10	Barn 11	Barn 12	Barn 12A	Pony Barn	Cafeteria Bldg.	
Process Wastewater Management																
Are there any signs that horse washing has been conducted outside of the designated washing stalls?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Are there any hoses or wash buckets observed outside the barns?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Are rubber mats being washed outside of the horse wash stalls?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Are there signs that vehicle/equipment washing has taken place in the horse barn area? Horse vans?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
Are WEP signs posted at each end of the barn and middle?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
Do storm drains have the words <i>Storm Drain - No Wastewater</i> stenciled nearby?	S	S	S	S	S	S	S	S	S	S	S	S	C	S	NA	One storm drain at Barn 12A.
Are horse washing stalls operational?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Are chemicals being handled and disposed of in a manner sufficient to prevent pollutants from entering the stormwater conveyance system?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
Are barns free of outside water spigots with the exception of the west side of Barn 11? (State Gaming Commission)	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
Dumpster Management																
Is ground around manure/bedding dumpsters free of manure and bedding?	S	S	S	S	S	C	S	C	C	C	S	S	S	S	NA	Minor amounts noted near bins 6, 8, 9, and 10.
Are there signs that dumpsters are releasing residual liquid to the ground?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Do any dumpsters appear to be at capacity or in need of emptying?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	NA	
Stormwater Management / Diversionsary Equipment																
Are gutters and downspouts in good condition and free of debris?	S	S	S	S	S	S	C	C	S	C	S	S	S	S	C	Barn 7 two downspouts missing. Barn 8 downspout missing. Barn 10 one section of horizontal. Maintenance Bldg. next to cafeteria has a broken downspout. Repairs are on-going.
Do stormwater drains show signs of improper wastewater disposal?	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	

Real-Time Dry Weather Monitoring Equipment	
Are solar powered wet sensors in northern and southern stormwater catch basins functional?	Yes/No, Facility's is working on fixing the sensor in southern area.
Is pump runtime meter on wet well pump control panel functioning? Is the daily log being filled out?	Runtime hour meter readings – Pump No. 1 - 201 hours, Pump No. 2 - 176 hours - Yes

IMMEDIATELY CONTACT THE WEP COORDINATOR WITH ANY IDENTIFIED DEFICIENCIES AT (516) 204-5093. IF NOT AVAILABLE CONTACT SECURITY AT GATE 6 BACK STRETCH AT (718) 641-4700 OR AQUEDUCT MAIN SECURITY AT (718) 659-3511.

Additional Notes: Talked to Officer Diggs concerning bins requiring clean-up.